



To our valued customers,

We hereby certify that to the best of our knowledge and belief that all domestic brass fittings furnished by Merit Brass Company are made from copper alloy C84400 in accordance with ASTM B584 with the following chemical analysis:

COPPER	79.74% – 81.00%
TIN	2.91% – 3.00%
LEAD	7.00% – 7.06%
ZINC	9.00% – 9.73%
NICKEL	0.00% – 0.28%
IRON	0.00% – 0.28%

Furthermore, the domestic brass fittings conform to ASME B16.15 and WW-P-460 125 pound class. 125 class pressure-temperature ratings range from 200 psi at -20°F to 125 psi at 400°F.

Sincerely,
MERIT BRASS COMPANY

A handwritten signature in black ink, appearing to read "Josh Schnippel".

Josh Schnippel
Quality Engineering Manager